

**SANITARY SEWER OVERFLOW
ANNUAL REPORT**

DATE: 02/16/10

FACILITY NAME: Marysville Water Reclamation Facility

OHIO NPDES PERMIT NO: 4PE00002001

PERIOD COVERED BY REPORT: January 1, 2009 - December 31, 2009

CONTACT PERSON

NAME: Rick Varner

TITLE: Superintendent of Wastewater

MAILING ADDRESS:

12901 Beecher Gamble Road
Marysville, OH 43040

TELEPHONE: 937-642-1036

EMAIL: rvarner@marysvilleohio.org

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION IN THIS REPORT AND ALL ATTACHMENTS. BASED ON MY INQUIRY OF THOSE PERSONS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION CONTAINED IN THE REPORT, I BELIEVE THAT THE INFORMATION IS TRUE, ACCURATE, AND COMPLETE.



Signature of Official

2/22/2010
Date

Superintendent of Wastewater
Title



Enter narrative analysis of WIB patterns by location, frequency and cause.

3/13/09 - Carriage Pump Station Sewershed (804 Lakeview Street) Water in Basement (WIB) due to debris blockage in public sanitary sewer. Line cleaned. Problem corrected

3/18/09 - Plum Street Sewershed (810 Collins Street) - Water in Basement (WIB) due to contractor performing "point repair" work on sanitary sewer. Temporary blockage due to inflatable plug" inserted in sewer and length of time of repair. Situation corrected when City draws were made aware of issue.